

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5275-1549:0502 Page 1 of 1

CATEGORY: 5275 -- GAS/VAPOR DETECTORS

LISTEE: INOVONICS WIRELESS CORPORATION 397 S. Taylor Ave., Louisville, CO 80027
Contact: Corey Leavitt (303) 209-7143 Fax (303) 939-8977
Email: cleavitt@inovonics.com

DESIGN: Model EN1245 CO detector battery operated with sounder, RF transmitter and integral base. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 3 Vdc Panasonic CR123A

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, NFPA 720, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a CO detector for use with Bosch Security Systems Fire Alarm Control Units Models D7212GV4, D7412GV4 and D9412GV4 (CSFM listing No. 7167-1615:0243), B3512, B4512 and B5512 (CSFM listing No. 7167-1615:0247), B8512G and B9512G (CSFM listing No. 7167-1615:0252); Honeywell Security Fire Alarm Control Units Models Vista-128FBP and Vista-250FBP (CSFM listing No. 7167-1645:0123), Safewatch Pro 3000 (CSFM listing No. 7167-1645:0150), Vista-128FBPT and Vista-250FBPT (CSFM listing No. 7167-1645:0197), Vista-128BPT, Vista-128BPTSIA and Vista-250BPT (CSFM listing No. 7167-1645:0198). For indoor use only. Refer to listee's Installation Instruction Manual for details.

05-07-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division