

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1549:0504

CATEGORY: Fire Alarm Control Unit Accessories/Misc. Devices

LISTEE: INOVONICS WIRLESS CORPORATION, 397 S. Taylor Ave., Louisville, CO 80027
Contact: Corey Leavitt (303) 209-7143 Fax (303) 939-8977
Email: cleavitt@inovonics.com

DESIGN: Model EH4104R RF Receiver and Model EH1115EOL RF Transmitter. Model EH4104R single zone RF receiver allows the use of one Model EH1115EOL RF transmitter utilizing spread spectrum technology to monitor fire alarm equipment. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: EH4104R: 11-14 Vdc, 400 mA
EH1115EOL: 3 Vdc, 60 mA

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a receiver and ransmitter for Control Unit Accessories. This receiver and transmitter must be used together.
Refer to Manufacturers Installation Instruction Manual for details.

06-12-2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division